



Report of Development Application

Pursuant to Section 4.15 of the Environmental Planning and Assessment Act 1979

APPLICATION DETAILS

Application No:	DA20/0085
Council File No:	D/2020/0085
Date of Lodgement:	26/02/2020
Applicant:	JL Nielsen 14 Wellington Ave TATTON NSW 2650
Proposal:	Dwelling, pool, shed and pool house
Development Cost	450000
Description of Modification:	N/A
Other Approvals:	Nil
Determination Body & Reason:	Officer Delegation 7.39
Assessment Officer:	Victoria Rice

SITE DETAILS

Subject Land:	22 Lakesend Pl LAKE ALBERT NSW 2650 Lot 57 DP 1235752
Owner:	JL Nielsen

REPORT

DESCRIPTION OF DEVELOPMENT

This application seeks consent for the construction of a dwelling with attached garage and workshop, swimming pool, pool house and shed.

THE SITE & LOCALITY

Location - the subject site is located on the western side of Lakesend Place approximately 75m from the bend in Lakesend Place.

Area- 1434m²

Occupations - the subject site is currently vacant.

Constraints and restrictions - 2.5 m wide easement along the western boundary of the site to drain sewage and stormwater. Restriction on building dwellings or structures within 5m of the western boundary.

MATTERS FOR CONSIDERATION PURSUANT TO SECTION 4.15(1)

The development has been assessed in accordance with the matters for consideration under Section 4.15 of the Environmental Planning and Assessment act 1979, and having regard to those matters, the following issues have been identified for further consideration:

Section 4.15(1)(a)(i) - The provisions of any environmental planning instrument (EPI)

Wagga Wagga Local Environmental Plan 2010 (LEP 2010)

Zoning of land (cl 2.2): R5

The development is permissible in the zone (cl. 2.3(1))

The development is consistent with the following objectives of the zone (cl. 2.3(2)):

- To provide residential housing in a rural setting while preserving, and minimising impacts on, environmentally sensitive locations and scenic quality.
- To ensure that large residential lots do not hinder the proper and orderly development of urban areas in the future.
- To ensure that development in the area does not unreasonably increase the demand for public services or public facilities.
- To minimise conflict between land uses within this zone and land uses within adjoining zones.
- To ensure that the clearing of native vegetation is avoided or minimised as far as is practicable.

The development is compliant with the relevant provisions of the LEP 2010. The following provisions have been identified for further discussion:

State Environmental Planning Policy No. 55

There is no indication that the site has previously been occupied by any use that could have led to contamination of the site. Furthermore, the land is not identified on Councils register of contaminated sites.

State Environmental Planning Policy (BASIX) 2004

A valid certificate has been lodged with the application and assessed as compliant.

Section 4.15(1)(a)(ii) - any proposed instrument that is or has been the subject of public consultation under this Act and that has been notified to the consent authority

There are a number of state environmental planning policies currently subject to

review, including some which have involved consultation and notification. With the exception of the following, none of these are applicable to this application.

Remediation of Land SEPP and repeal of State Environmental Planning Policy 55

The draft SEPP will not impact on the assessment of this application under SEPP 55 with regard to the potential contamination of this site and its suitability for the proposed development.

Section 4.15(1)(a)(iii) - any development control plan

Wagga Wagga Development Control Plan 2010

The development is compliant with the relevant provisions of the DCP 2010. The following provisions have been identified for further discussion:

1.10 Notification of a Development Application

The application has been notified in accordance with the notification provisions outlined in Section 1.10 of the WWDCP. The application was notified between 12 March to 19 March 2020. No submissions were received.

1.11 Complying with the Wagga Wagga Development Control Plan 2010

The controls in the DCP support the Guiding Principles of the Plan and principles and objectives within the various sections. Except as varied elsewhere in this Plan, all Development Applications, Section 96 Applications and Section 82A Applications should aim to satisfy all stated objectives and controls.

Whilst all developments should aim to satisfy all controls within the DCP, it is acknowledged that there may be circumstances where it may not be possible to achieve strict compliance.

Council may consent to an application which departs from any control, whether a "numeric" or non-numeric control. In such cases, a written submission must be lodged with the Development Application.

Where an application involves the variation of one or more controls within the DCP Council staff have delegation to approve variations but limited to the following circumstances;

- *Where adequate justification is provided by the applicant for the number of controls being varied and,*
- *Any development, other than development that is for multi dwelling housing, where a variation to any numerical control by greater than 10% is proposed, and*
- *Where no objections have been received in relation to any numerical control that is being varied by greater than 10%, and*
- *Where the number of submissions in the form of objections received in response to*

an advertised or notified development application, is less than 10.

The application proposes a variation to C2 of Section 9.3.7 of the DCP. However no objections have been received and therefore Council staff have delegation to approve such an application if justification has been submitted and the proposal is acceptable.

The issues surrounding the variation have been discussed throughout this report, particular attention is drawn to Section 9.3.7 of the report.

9.3.7 Side and Rear setbacks

C2 Any point of a building must have a setback from the side boundary nearest to that point of at least:

- a) If the lot is in Zone R5 a setback of 2m, or*
- b) If the lot is in Zone RU1, RU2 or RU4 a setback of 10m.*

The shed is setback 1m from the side (southern) boundary and over 5m from the rear boundary. The control requires a 2m setback from the side boundary. The applicant has provided the following justification for the variation to the setback:

- The streetscape visual impact of the shed with the current setback from the southern boundary is negligible due to the shed's significant setback from the street.
- The National Construction Code permits an outbuilding to be built on the boundary, most structures however are best practice to be kept 900mm to 1m off boundaries.

Council staff add that the shed is unlikely to have unreasonable impact on the amenity of the adjoining lot to the south. The adjoining lot to the north has a dwelling and the site to the south is vacant. The proposed shed is located to the rear of a large residential lot and therefore not likely to produce excessive overshadowing of potential private open space. The immediate area is characterised by large lots in a residential setting, the size of the lot lends themselves to smaller setbacks as opposed to other lots in the R5 zone. As such a reduction in setback is acceptable as there will be adequate separation between buildings for landscaping, privacy, light and ventilation. The proposed shed is considered to be consistent with the expected character of the vicinity. The proposed development is considered to meet the relevant objectives of this section and the variation is supported.

Section 4.15(1)(a)(iiia) - any planning agreement that has been entered into under section 7.4, or any draft planning agreement that a developer has offered to enter into under section 7.4

No related planning agreement has been entered into under section 7.4.

Section 4.15(1)(a)(iv) - the regulation

Matters prescribed by the Environmental Planning and Assessment Regulation 2000 have been satisfied, including the addition of prescribed conditions.

Section 4.15(1)(b) - The likely impacts of that development, including

environmental impacts on both the natural and built environments, and social and economic impacts in the locality

The likely impacts of the development have been considered and are deemed satisfactory.

Section 4.15(1)(c) - The suitability of the site for the development

Matters relating to the suitability of the site for this development have been considered and the site is deemed suitable for the development.

(d) - any submissions made in accordance with this Act or the Regulations

No submissions have been received.

(e) - the public interest

It is considered that this application will not have a detrimental affect on the public interest.

Other Legislative Requirements

Section 5AA and Part 7 of the *Biodiversity Conservation Act 2016* (Test for determining whether proposed development or activity likely to significantly affect threatened species or ecological communities, or their habitats)

The development is in a residential zone and not removing any vegetation; the development will have minimal impact and not impact on any threatened species in the vicinity. No further assessment is required under this section.

Council Policies

Policy 046 - Processing Development Applications lodged by Councillors, staff and individuals of which a conflict of interest may arise, or on Council owned land.

No declaration has been made that would require action under this policy.

Comments from Internal Referrals

No comments have been received from internal referrals undertaken.

Development Contributions

Contributions were paid at subdivision stage for a single dwelling on this block, therefore no further contributions are required.

Conclusion

The development is considered to be satisfactory based on the foregoing assessment. The proposal complies with the requirements of the Environmental Planning and Assessment Act 1979, the Building Code of Australia (Housing Provisions) and Councils Policies. No objections to the proposal were received.

Recommendation

It is recommended that application number DA20/0085 for Dwelling, pool, shed and pool house be approved, subject to the following conditions:-

CONDITIONS

A. SCHEDULE A – Reasons for Conditions

The conditions of this consent have been imposed for the following reasons:

- A.1 To ensure compliance with the terms of the Environmental Planning and Assessment Act 1979 and Regulation 2000.
- A.2 Having regard to Council's duties of consideration under Section 4.15 and 4.17 of the Act.
- A.3 To ensure an appropriate level of provision of amenities and services occurs within the City and to occupants of sites.
- A.4 To improve the amenity, safety and environmental quality of the locality.
- A.5 Having regard to environmental quality, the circumstances of the case and the public interest.
- A.6 Having regard to the Wagga Wagga Development Control Plan 2010.
- A.7 To help retain and enhance streetscape quality.
- A.8 Ensure compatibility with adjoining and neighbouring land uses and built form.
- A.9 To protect public interest, the environment and existing amenity of the locality.
- A.10 To minimise health risk to neighbouring residents and workers.

B. SCHEDULE B – Deferred Commencement Conditions

N/A

C. SCHEDULE C – Conditions

Approved Plans and Documentation

- C.1 The development must be carried out in accordance with the approved plans and specifications as follows.

Plan/Doc No.	Plan/Doc Title	Prepared by	Issue	Date
19022	WHS, Site Plan & Floor Plan	Sewell Design Pty Ltd	E	30/1/2020
19022	Elevations, Sections & BASIX	Sewell Design Pty Ltd	E	30/1/2020
2909241731	Architectural Drawings - Elevations	Optimum Sheds	-	-
2909241731	Architectural Drawings - Floor Plan	Optimum Sheds	-	-
13-6293-S47	Brooklyn Pool and Spa Range	Summermore Pty Ltd	D	Feb 2016
1072944S_02	BASIX Certificate	Sewell Design Pty Ltd	2	30/1/2020
-	Statement of Environmental Effects	Joanne Nielsen	-	30/1/2020

The Development Application has been determined by the granting of consent subject to and as amended by the conditions of development consent specified below.

NOTE: Any modifications to the proposal shall be the subject of an application under Section 4.55 of the Environmental Planning and Assessment Act, 1979.

Requirements before a Construction Certificate can be issued

C.2 Prior to the issue of Construction Certificate the applicant must lodge a bond with Council of:-

\$1000.00 for security deposit on the kerb and gutter and footpath

Plus a non-refundable administration fee as per Councils fees and charges.

NOTE 1: Applicants will be required to contact Council PRIOR to making the payment to arrange a bond (BKG) number. This must be done prior to making payment at Council's customer service desk.

NOTE 2: In lieu of payment, the applicant can with written authorisation from their builder, utilise an ongoing bond should their builder hold an ongoing bond.

NOTE 3: All monetary conditions are reviewed annually, and may change on 1 July each year.

NOTE 4: Works in the form of driveways, kerb and gutter and footpath may require you to obtain a Section 138 Roads Act 1993 approval. Please contact Councils Road Reserve Officer on 1300 292 442 prior to undertaking such works.

NOTE 5: Council will accept a once off security deposit for the kerb and gutter and footpath for applicants who lodge multiple DA's with council. If the applicant has security deposits held by Council for kerb and gutter and footpath at the time of Construction Certificate application, then Council may waive the need for an additional bond to be paid.

NOTE 6: The bond held on the kerb and gutter and footpath is fully refundable upon completion of all works and upon inspection by Council to ensure that any damage to Council infrastructure has been repaired. The bond will not be refunded in the event that damage done to Council's infrastructure is not repaired to the satisfaction of Council. All damage is to be repaired at the full cost of the applicant

Requirements before the commencement of any works

C.3 Prior to works commencing on site, toilet facilities must be provided, at or in the vicinity of the work site on which work involved in the erection or demolition of a building is being carried out, at the rate of one toilet for every 20 persons or part of 20 persons employed at the site. Each toilet provided must be:

a) a standard flushing toilet connected to a public sewer, or

- b) if that is not practicable, an accredited sewage management facility approved by Council, or
- c) if that is not practicable, any other sewage management facility approved by Council.

NOTE 1: The provision of toilet facilities in accordance with this condition must be completed before any other work is commenced and the toilet facility must not be removed without the prior written approval of Council.

NOTE 2: "Vicinity" in this condition is defined to mean within 50 metres of the subject building site.

NOTE 3: The toilet facilities are to comply with all WORK COVER NSW requirements.

- C.4 A CONSTRUCTION CERTIFICATE must be obtained pursuant to Section 6.7 of the Environmental Planning and Assessment Act 1979, as amended from either Council or an accredited certifying authority certifying that the proposed works are in accordance with the Building Code of Australia PRIOR to any works commencing.

NOTE 1: No building, engineering, excavation work or food premises fitout must be carried out in relation to this development until the necessary Construction Certificate has been obtained.

NOTE 2: YOU MUST NOT COMMENCE WORK UNTIL YOU HAVE RECEIVED THE CONSTRUCTION CERTIFICATE, even if you made an application for a Construction Certificate at the same time as you lodged this Development Application.

NOTE 3: It is the responsibility of the applicant to ensure that the development complies with the provision of the Building Code of Australia in the case of building work and the applicable Council Engineering Standards in the case of subdivision works. This may entail alterations to the proposal so that it complies with these standards.

- C.5 Prior to works commencing a container must be erected on site for the enclosure of all building rubbish and debris, including that which can be wind blown. The enclosure shall be approved by Council and be retained on site at all times prior to the disposal of rubbish at a licenced Waste Management Centre.

Materials and sheds or machinery to be used in association with the construction of the building must not be stored or stacked on Council's footpath, nature strip, reserve or roadway.

NOTE 1: No building rubbish or debris must be placed, or be permitted to be placed on any adjoining public reserve, footway, road or private land.

NOTE 2: Weighbridge certificates, receipts or dockets that clearly identify where waste has been deposited must be retained. Documentation must include quantities and nature of the waste. This documentation must be provided to Council prior to application for an Occupation Certificate for the development.

NOTE 3: The suitable container for the storage of rubbish must be retained on site until an Occupation Certificate is issued for the development.

C.6 Prior to the commencement of works erosion and sediment control measures are to be established and maintained to prevent silt and sediment escaping the site or producing erosion. This work must be carried out and maintained in accordance with Council's:-

- a) Development Control Plan 2010 (Section 2.6 and Appendix 2)
- b) Erosion and Sediment Control Guidelines for Building Sites; and
- c) Soils and Construction Volume 1, Managing Urban Stormwater

Prior to commencement of works, a plan illustrating these measures shall be submitted to, and approved by, Council.

NOTE: All erosion and sediment control measures must be in place prior to earthworks commencing.

C.7 Prior to works commencing on site:

- i) Council must be notified of any damage to kerb and gutter and footpath fronting the site. The absence of such notification shall indicate that no damage exists and the applicant shall be responsible for the repair of any damage to kerb and gutter or footpath fronting the site.
- ii) Satisfactory protection for existing public infrastructure must be provided and maintained throughout the construction period.

C.8 A Section 68 Approval must be obtained from Council prior to any sewer or stormwater work being carried out on the site.

The licensed plumber must submit to Council, at least two (2) days prior to the commencement of any plumbing and drainage works on site a "Notice of Works".

NOTE: A copy of the Notice of Works form can be found on Council's website.

Requirements during construction or site works

- C.9 Vehicular access within the road reserve must be constructed to Council standards, at full cost to the developer, by a licensed Council approved contractor. A list of Contractors can be found on Council's website at- <https://wagga.nsw.gov.au/city-of-wagga-wagga/engineering-services/traffic-and-transport/working-in-a-road-reserve-or-footpath> Driveway design and grades shall comply with AS2890.1: 2004 (or as amended) and Council's Engineering Guidelines for Subdivisions and Developments.
- C.10 The Builder must at all times maintain, on the job, a legible copy of the plans and specifications approved with the Construction Certificate.

- C.11 All excavation and backfilling associated with the erection/demolition of the building must be properly guarded and protected to prevent them from being dangerous to life or property.
- C.12 Any alterations or additions marked by Council on the approved plans and/or the specifications must be carried into effect.
- C.13 The concrete slab floor shall be treated against termites in accordance with AS 3660-1 2000 Termite Management:
- a) NON CHEMICAL - where a non chemical treatment (physical barriers) is to be used the applicant shall submit details to Council prior to any work commencing.
 - b) CHEMICAL RETICULATION - where a chemical method of treatment is to be used by way of reticulation, details shall be provided to Council for approval prior to installation accompanied by a signed maintenance contract with a Pest Control Operator.
- Applicants and owners are to ensure that an annual inspection is undertaken to determine need for treatment.
- c) Upon installation of the method of treatment, a Certificate shall be issued to Council by the licensed installer of the system certifying that the system installed is in accordance with AS 3660-1 and in accordance with any specific requirements of the Council.
 - d) A durable notice must be permanently fixed to the building in the electricity meter box indicating:
 - i) The method of protection
 - ii) The date of installation of the system
 - iii) Where a chemical barrier is used, its life expectancy as listed on the National Registration Authority label.
 - iv) The need to maintain and inspect the system on a regular basis.
- C.14 The permitted construction hours are Monday to Friday 7.00am to 6.00pm and Saturday 7.00am to 5.00pm, excepting public holidays. All reasonable steps must be taken to minimise dust generation during the demolition and/or construction process. Demolition and construction noise is to be managed in accordance with the Office of Environment and Heritage Guidelines.
- C.15 All earthworks, filling, building, driveways or other works, must be designed and constructed (including stormwater drainage if necessary) so that at no time, will any ponding of stormwater occur on adjoining land as a result of this development.
- C.16 The developer is to maintain all adjoining public roads to the site in a clean and tidy state, free of excavated "spoil" material.
- C.17 A Compliance Certificate for the plumbing and drainage work identified in Column 1 at the times specified in Column 2 must be obtained from Council.

COLUMN 1	COLUMN 2
Internal Sewer Drainage	When all internal plumbing and drainage work is installed and prior to concealment.
External Sewer Drainage	When all external plumbing and drainage work is installed and prior to concealment.
Stormwater Drainage	When all external stormwater drainage work is installed and prior to concealment.
Final	Prior to occupation of the building or structure.

- C.18 If the Council is appointed as the Principal Certifying Authority the applicant must obtain a Compliance Certificate, pursuant to Section 109C of the Environmental Planning and Assessment Act 1979, as amended, from Council or an accredited certifying authority, certifying compliance with the Building Code of Australia and the Swimming Pool Act 1992, for the stages of construction listed in Column 1. For the purposes of obtaining the Compliance Certificate the works must be inspected by the accredited certifying authority at the times specified in Column 2.

COLUMN 1	COLUMN 2
Footings / Coping	When the pool is in position and all reinforcement has been placed in position.
Fencing	When the pool and all fencing, gates and locks have been completed and prior to water being placed in the pool.

NOTE 1: A final Occupation Certificate in relation to the work cannot be issued by Council or an accredited certifying authority until all Compliance Certificates required by this condition have been issued or registered with Council.

NOTE 2: The above Compliance Certificates are required whether or not the work has been inspected by a Structural Engineer, a lending authority or any other person. If the Compliance Certificates are not issued Council may refuse to issue a Building Certificate under Section 149A and D of the Environmental Planning and Assessment Act 1979, as amended.

- C.19 All work is to comply with the Building Code of Australia, the Swimming Pools Act 1992 and Swimming Pools Regulations 2008. In this regard the following minimum requirements will apply:

- a) a minimum 1.2 metre high child resistant barrier is to be provided to enclose the swimming pool,
- b) gate/s leading into the pool area is to be fitted with an outward opening, self closing and latching gate,
- c) pool latches are to be located 1.5 metres high above the ground level,
- d) a resuscitation poster is to be affixed within the pool area.

NOTE: Prior to the issue of an occupation certificate, the owner of the property shall supply Council with documentary evidence that the completed swimming pool has been registered at www.swimmingpoolregister.nsw.gov.au <<http://www.swimmingpoolregister.nsw.gov.au>> as required by the amended Swimming Pool Act. In sewerred areas, the swimming pool backwash pipe must be connected to the house sewer drainage system in accordance with Clause 10.9 and Figure 10.2 of AS/NZS 3500.2.2003 Sanitary Plumbing and Sanitary Drainage. This connection can be via a suitable existing gully or, alternatively, a gully can be cut into the house drainage line for this purpose.

If alterations to the existing house drainage lines are required, a Compliance Certificate must be obtained pursuant to Section 109C of the Environmental Planning and Assessment Act 1979 from Council or an accredited certifying authority at the stages of construction listed in Column 1 certifying compliance with AS/NZS 3500.2003. For the purpose of obtaining the Compliance Certificate the works must be inspected by Council or an accredited certifying authority at the times specified in Column 2.

COLUMN 1	COLUMN 2
External Drainage Alterations	When all external plumbing work is installed and prior to concealment.
Final	At the completion of the installation of the pool.

- C.20 A 1.8 metre high boundary fence (as measured from the inside of the fence) is required where the property boundary fence is used as a part of the swimming pool barrier. This is to have a 900 mm non climbable zone on the inside face of the fence to comply with AS1926.2012 Swimming Pool Safety Standards.

Requirements prior to issue of an Occupation Certificate or prior to operation

- C.21 Prior to issue of an occupation certificate the building number must be displayed in a position clearly visible from the street in letters having a height of not less than 75 mm. The number must be visible against the background on which it is placed.
- C.22 All retaining walls shown on the approved plans shall be completed prior to the issue of a Final Occupation Certificate.
- C.23 An Occupation Certificate, must be obtained pursuant to Section 6.9 of the Environmental Planning and Assessment Act 1979, from either Council or an accredited certifying authority, prior to occupation of the building.

In order to obtain this, the "Final Occupation Certificate" form must be completed and submitted to Council with all required attachments - failure to submit the completed Occupation Certificate Application form will result in an inability for Council to book and subsequently undertake Occupation Certificate inspection.

NOTE: The issuing of an Occupation Certificate does not necessarily indicate that all conditions of development consent have been complied with. The applicant is responsible for ensuring that all conditions of development consent are complied with.

- C.24 A final inspection must be carried out upon completion of plumbing and drainage work and prior to occupation of the development, prior to the issuing of a final plumbing certificate Council must be in possession of Notice of Works, Certificate of Compliance and Works as Executed Diagrams for the works. The works as Executed Diagram must be submitted in electronic format in either AutoCAD or PDF file in accordance with Council requirements.

All plumbing and drainage work must be carried out by a licensed plumber and drainer and to the requirements of the Plumbing and Drainage Act 2011.

NOTE: Additional fees for inspections at the Plumbing Interim Occupancy / Plumbing Occupation stage may apply. This will depend on the number of inspections completed at this stage of the work/s.

- C.25 Prior to the issue of an Occupation Certificate a Water Plumbing Certificate from Riverina Water County Council shall be submitted to Council.

NOTE 1: The applicant is to obtain a Plumbing Permit from Riverina Water County Council before any water supply/plumbing works commence and a Compliance Certificate upon completion of the works. Contact Riverina Water County Council's Plumbing Inspector on 6922 0618. Please be prepared to quote your Construction Certificate number.

General requirements

- C.26 Any earthworks (including any structural support or other related structure for the purposes of the development):
- (a) must not cause a danger to life or property or damage to any adjoining building or structure on the lot or to any building or structure on any adjoining lot, and
 - (b) must not redirect the flow of any surface or ground water or cause sediment to be transported onto an adjoining property, and
 - (c) retained material must have a gradient of at least 5%, and
 - (d) must be constructed in accordance with the approved plans for such work(s).

- C.27 No part of the development, including cut, fill, or footings is to encroach the easement. All backwash water or water discharged from the pool during emptying must be discharged into Council's sewer in accordance with the requirements of AS/NZS 3500 and the Plumbing Code of Australia. Under no circumstances must water be discharged to the street.

NOTE: Discharge from Pools in unsewered areas will be in a method approved by Council.

- C.28 The proposed filter and pump must be operated in accordance with the Protection of the Environment Operations (Noise Control) Regulation 2008 which restricts the times of operation. Restrictions apply between 8.00 pm and 7.00 am on weekdays and Saturdays and 8.00 pm to 8.00 am on Sundays and public holidays.

NOTE 1: The swimming pool water, together with the treatment processes and facilities must comply with the requirements of the Public Health Act 2010 and Public Health Regulation 2012.

In this regards -

- pH needs to be between 7.2 and 7.8
- Alkalinity needs to be between 80mg/L and 200mg/L
- Free chlorine needs to be between 3mg/L and 10mg/L
- Combined chlorine needs to be less than 1mg/L
- Cyanuric acid (if used) must be between 30mg/L and 100mg/L

NOTE 2: For all pools in “septic areas”, the applicant must ensure that water discharged from the pool does not enter the septic tank or adversely impact on the septic disposal area or enter a drainage line.

D. SCHEDULE D – Activity Approval Conditions (Section 68)

N/A

E. SCHEDULE E – Prescribed Conditions

Conditions under this schedule are prescribed conditions for the purposes of section 4.17 (11) of the Environmental Planning and assessment Act 1979.

E.1 Fulfilment of BASIX commitments (clause 97A EP&A Reg 2000)

The commitments listed in any relevant BASIX Certificate for this development must be fulfilled in accordance with the BASIX Certificate Report, Development Consent and the approved plans and specifications.

E.2 Compliance with Building Code of Australia and insurance requirements under the Home Building Act 1989 (clause 98 EP&A Reg 2000)

- (1) For development that involves any building work, the work must be carried out in accordance with the requirements of the Building Code of Australia.
- (2) In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract of insurance shall be in force before any building work authorised to be carried out by the consent commences.
- (3) For a temporary structure that is used as an entertainment venue, the temporary structure must comply with Part B1 and NSW Part H102 of Volume One of the Building Code of Australia.

NOTE 1: This condition does not apply:

- (a) to the extent to which an exemption is in force under clause 187 or 188 of the Environmental Planning and Assessment Regulation 2000 (the Regulation), subject to the terms of any condition or requirement referred to in clause 187(6) or 188(4) of the Regulation, or

- (b) to the erection of a temporary building, other than a temporary structure to which part (3) of this condition applies.

NOTE 2: In this condition, a reference to the Building Code of Australia is a reference to that Code as in force on the date the application is made for the relevant:

- (a) development consent, in the case of a temporary structure that is an entertainment venue, or
- (b) construction certificate, in every other case.

NOTE 3: There are no relevant provisions in the Building Code of Australia in respect of temporary structures that are not entertainment venues.

E.3 Erection of signs (clause 98A EP&A Reg 2000)

For development that involves any building work, subdivision work or demolition work, a sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:

- (a) showing the name, address and telephone number of the principal certifying authority for the work, and
- (b) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
- (c) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

NOTE 1: This condition does not apply in relation to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

NOTE 2: This condition does not apply in relation to Crown building work that is certified, in accordance with section 6.28 of the Environmental Planning and Assessment Act 1979, to comply with the technical provisions of the State's building laws.

NOTE 3: Principal certifying authorities and principal contractors must also ensure that signs required by this clause are erected and maintained.

E.4 Notification of Home Building Act 1989 requirements (clause 98B EP&A Reg 2000)

Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the principal certifying authority for the development to which the work relates (not being the council) has given the council written notice of the following information:

- (a) in the case of work for which a principal contractor is required to be appointed:
 - i) the name and licence number of the principal contractor, and

- ii) the name of the insurer by which the work is insured under Part 6 of that Act,
- (b) in the case of work to be done by an owner-builder:
 - i) the name of the owner-builder, and
 - ii) if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under this condition becomes out of date, further work must not be carried out unless the principal certifying authority for the development to which the work relates (not being the council) has given the council written notice of the updated information.

NOTE: This condition does not apply in relation to Crown building work that is certified, in accordance with section 6.28 of the Environmental Planning and Assessment Act 1979, to comply with the technical provisions of the State's building laws.

E.5 Entertainment venues (clause 98C EP&A Reg 2000)

If the development involves the use of a building as an entertainment venue, the development shall comply with the requirements set out in Schedule 3A of the Environmental Planning and Assessment regulation 2000.

E.6 Maximum capacity signage (clause 98D EP&A Reg 2000)

For the following uses of a building: a sign must be displayed in a prominent position in the building stating the maximum number of persons permitted in the building if the development consent for the use contains a condition specifying the maximum number of persons permitted in the building:

- (a) entertainment venue,
- (b) function centre,
- (c) pub,
- (d) registered club,
- (e) restaurant.

NOTE: Words and expressions used in this condition have the same meanings as they have in the Standard Instrument.

E.7 Shoring and adequacy of adjoining property (clause 98E EP&A Reg 2000)

If the development involves an excavation that extends below the level of the base of the footings of a building, structure or work (including any structure or work within a road or rail corridor) on adjoining land, the person having the benefit of the development consent must, at the person's own expense:

- (a) protect and support the building, structure or work from possible damage from the excavation, and

- (b) where necessary, underpin the building, structure or work to prevent any such damage.

NOTE: This condition does not apply if the person having the benefit of the development consent owns the adjoining land or the owner of the adjoining land has given consent in writing to that condition not applying.

F. SCHEDULE F – General Terms of Approval (Integrated Development)

N/A

Report Prepared & approved by: Victoria and Sam



Paul O'Brien
Manager Development Assessment & Building Certification

Date: 22/04/2020