



City of
Wagga Wagga

Notice of Determination of Development Application

Environmental Planning and Assessment Act 1979

Notice is hereby given of the determination by Council to the Modification of the above Development Application pursuant to Section 4.55 of the Environmental Planning & Assessment Act, 1979.

Modification Number:	DA20/0014.01
Development Application Modified:	DA20/0014
Type of Modification:	s4.55(1)
Applicant:	Structure Building Pty Ltd 49 Barmedman Ave GOBBAGOMBALIN NSW 2650
Land to be Developed:	1/615 Gelston Park Rd GELSTON PARK NSW 2650 Lot 2 DP 286397
Description of Modification:	Delete C2 (Contributions)
Determination:	Approved
Description of Development:	Remove 7.11 Contributions
Date of Determination of Modification:	20/04/2020

On behalf of the Council

Paul O'Brien
Manager Development Assessment & Building Certification

Notice of Determination

Lapsing of the Consent

This modification does not alter the lapsing date of the Consent. It remains as that shown on the original determination.

Review of Determination

Where Council is the consent authority, Section 8.2 of the Environmental Planning and Assessment Act 1979, provides that the applicant may request the Council to review the determination. A request for review cannot be made after the period within which any appeal may be made to the Court has expired if no appeal was made. There is no right to review a determination of a complying development certificate, designated development, or Crown Development.

Right of Appeal

Where an applicant is dissatisfied with this decision, Section 8.7 of the Environmental Planning and Assessment Act 1979 provides a right to appeal the decision to the Land and Environment Court within a period of 6 months from the date the decision is notified or registered on the NSW planning portal or after the date of deemed refusal under section 8.11.

CONDITIONS OF CONSENT FOR APPLICATION NO. AS MODIFIED BY APPLICATION NO. DA20/0014.01

A. SCHEDULE A - Reasons for Conditions

The conditions of this consent have been imposed for the following reasons:

- A.1 To ensure compliance with the terms of the Environmental Planning and Assessment Act 1979 and Regulation 2000.
- A.2 Having regard to Council's duties of consideration under Section 4.15 and 4.17 of the Act.
- A.3 To ensure an appropriate level of provision of amenities and services occurs within the City and to occupants of sites.
- A.4 To improve the amenity, safety and environmental quality of the locality.
- A.5 Having regard to environmental quality, the circumstances of the case and the public interest.
- A.6 Having regard to the Wagga Wagga Development Control Plan 2010.
- A.7 To help retain and enhance streetscape quality.
- A.8 Ensure compatibility with adjoining and neighbouring land uses and built form.
- A.9 To protect public interest, the environment and existing amenity of the locality.
- A.10 To minimise health risk to neighbouring residents and workers.

B. SCHEDULE B - Deferred Commencement Conditions

N/A

C. SCHEDULE C - Conditions

Approved Plans and Documentation

- C.1 The development must be carried out in accordance with the approved plans and specifications as follows.

Plan/DocNo.	Plan/Doc Title	Prepared by	Issue	Date
	Statement of Environmental Effects	Kristy Campbell		15/1/20
152-19 (2/10)	Overall Site Plan	Wink+Co	B	8/11/19
152-19 (3/10)	Site Plan	Wink+Co	B	8/11/19
152-19 (4/10)	Floor Plan	Wink+Co	B	8/11/19
152-19 (6/10)	Elevations	Wink+Co	B	8/11/19
152-19 (7/10)	Elevations	Wink+Co	B	8/11/19
152-19 (10/10)	BASIX Notes	Wink+Co	B	8/11/19
	BASIX Certificate No 1054910S	Structure Building PTY LTD		28/10/19

The Development Application has been determined by the granting of consent subject to and as amended by the conditions of development consent specified below.

NOTE: Any modifications to the proposal shall be the subject of an application under Section 4.55 of the Environmental Planning and Assessment Act, 1979.

Requirements before a Construction Certificate can be issued

C.2 DELETED

- C.3 Prior to the issue of a Construction Certificate, a geotechnical study must be submitted with the "Application to Install an On-Site Sewage Management System" to determine the suitability of the site with respect to the on-site disposal of waste water. An On-Site Sewage Management System Application together with the geotechnical report shall be assessed and approved by Council prior to carrying out any works on the site.

This study must be carried out by an appropriately qualified geotechnical Soil Consultant, with associated testing being conducted by a NATA registered laboratory. Matters such as geology, stratigraphy (in particular, soil profile and permeability) must be addressed.

The study must also state whether or not the proposed dwelling and the proposed waste water disposal area are located in a position and are of a design and capacity to ensure that all waste water generated from the activities carried out on site can be disposed of on the site without causing nuisance and/or pollution, both in the short and the long term.

NOTE 1: Alterations/modifications to the premise or replacement of disposal areas and or the On-site Sewage Management Systems require a geotechnical soil report to determine if the current system can manage additional loads and/or if the current disposal areas are adequately sized to effectively treat waste water generated by the activities on the premise.

NOTE 2: As a site investigation will need to be undertaken in order to determine the design of the floor slab and/or footings, it is suggested that the required geo-technical study with respect to on-site disposal of effluent be carried out at the same time. This should minimise investigation time and costs.

NOTE 3: The final location of the dwelling on the land may be determined by the findings and recommendations of the required geo-technical study. The location of the dwelling should therefore not be finalised until the results of the geo-technical study are known.

- C.4 Prior to the issue of a Construction Certificate, it must be demonstrated that the On-Site Sewage Management System and its associated disposal area situated more than 40m away from drainage channels, 100m away from rivers, lakes, water body, etc and 250m away from domestic ground water wells.
- C.5 Prior to release of the Construction Certificate, an application to install an On-Site Sewage Management System must be submitted to and approved by Council. The On-site Sewage Management System tank must be installed on the land and the premises connected thereto, in accordance with the provisions of the Local Government Act 1993 Part 1 Approvals and the Local Government (General) Regulation 2005.

NOTE: A Section 68 approval for sanitary plumbing and drainage works must be obtained in conjunction with the On-site Sewage Management System application.

Requirements before the commencement of any works

- C.6 Prior to works commencing on site, toilet facilities must be provided, at or in the vicinity of the work site on which work involved in the erection or demolition of a building is being carried out, at the rate of one toilet for every 20 persons or part of 20 persons employed at the site. Each toilet provided must be:

- a) a standard flushing toilet connected to a public sewer, or
- b) if that is not practicable, an accredited sewage management facility approved by Council, or
- c) if that is not practicable, any other sewage management facility approved by Council.

NOTE 1: The provision of toilet facilities in accordance with this condition must be completed before any other work is commenced and the toilet facility must not be removed without the prior written approval of Council.

NOTE 2: "Vicinity" in this condition is defined to mean within 50 metres of the subject building site.

NOTE 3: The toilet facilities are to comply with all WORK COVER NSW requirements.

- C.7 A CONSTRUCTION CERTIFICATE must be obtained pursuant to Section 6.7 of the Environmental Planning and Assessment Act 1979, as amended from either Council or an accredited certifying authority certifying that the proposed works are in accordance with the Building Code of Australia PRIOR to any works commencing.

NOTE 1: No building, engineering, excavation work or food premises fitout must be carried out in relation to this development until the necessary Construction Certificate has been obtained.

NOTE 2: YOU MUST NOT COMMENCE WORK UNTIL YOU HAVE RECEIVED THE CONSTRUCTION CERTIFICATE, even if you made an application for a Construction Certificate at the same time as you lodged this Development Application.

NOTE 3: It is the responsibility of the applicant to ensure that the development complies with the provision of the Building Code of Australia in the case of building work and the applicable Council Engineering Standards in the case of subdivision works. This may entail alterations to the proposal so that it complies with these standards.

- C.8 Prior to works commencing a container must be erected on site for the enclosure of all building rubbish and debris, including that which can be wind blown. The enclosure shall be approved by Council and be retained on site at all times prior to the disposal of rubbish at a licenced Waste Management Centre.

Materials and sheds or machinery to be used in association with the construction of the building must not be stored or stacked on Council's footpath, nature strip, reserve or roadway.

NOTE 1: No building rubbish or debris must be placed, or be permitted to be placed on any adjoining public reserve, footway, road or private land.

NOTE 2: Weighbridge certificates, receipts or dockets that clearly identify where waste has been deposited must be retained. Documentation must include quantities and nature of the waste. This documentation must be provided to Council prior to application for an Occupation Certificate for the development.

NOTE 3: The suitable container for the storage of rubbish must be retained on site until an Occupation Certificate is issued for the development.

C.9 Prior to the commencement of works erosion and sediment control measures are to be established and maintained to prevent silt and sediment escaping the site or producing erosion. This work must be carried out and maintained in accordance with Council's:-

- a) Development Control Plan 2010 (Section 2.6 and Appendix 2)
- b) Erosion and Sediment Control Guidelines for Building Sites; and
- c) Soils and Construction Volume 1, Managing Urban Stormwater

Prior to commencement of works, a plan illustrating these measures shall be submitted to, and approved by, Council.

NOTE: All erosion and sediment control measures must be in place prior to earthworks commencing.

C.10 A Section 68 Approval must be obtained from Council prior to any sewer or stormwater work being carried out on the site.

The licensed plumber must submit to Council, at least two (2) days prior to the commencement of any plumbing and drainage works on site a "Notice of Works".

NOTE: A copy of the Notice of Works form can be found on Council's website.

Requirements during construction or site works

- C.11 New construction shall comply with section 5 (BAL 12.5) Australian Standard AS3959-2009 "Construction of buildings in bush fire-prone areas" and section A3.7 Addendum Appendix 3 of "Planning for Bush fire Protection".
- C.12 At the commencement of building works and in perpetuity the property around the building to a distance of 20 metres, shall be maintained as an inner protection area (IPA) as outlined within section 4.1.3 and Appendix 5 of Planning for Bush Fire Protection 2006 and the NSW Rural Fire Service's document Standards for asset protection zones.
- C.13 The Builder must at all times maintain, on the job, a legible copy of the plans and specifications approved with the Construction Certificate.
- C.14 All excavation and backfilling associated with the erection/demolition of the building must be properly guarded and protected to prevent them from being dangerous to life or property.
- C.15 The concrete slab floor shall be treated against termites in accordance with AS 3660-1 2000 Termite Management:
 - a) NON CHEMICAL - where a non chemical treatment (physical barriers) is to be used the applicant shall submit details to Council prior to any work commencing.

- b) CHEMICAL RETICULATION - where a chemical method of treatment is to be used by way of reticulation, details shall be provided to Council for approval prior to installation accompanied by a signed maintenance contract with a Pest Control Operator.
- Applicants and owners are to ensure that an annual inspection is undertaken to determine need for treatment.
- c) Upon installation of the method of treatment, a Certificate shall be issued to Council by the licensed installer of the system certifying that the system installed is in accordance with AS 3660-1 and in accordance with any specific requirements of the Council.
- d) A durable notice must be permanently fixed to the building in the electricity meter box indicating:
- i) The method of protection
 - ii) The date of installation of the system
 - iii) Where a chemical barrier is used, its life expectancy as listed on the National Registration Authority label.
 - iv) The need to maintain and inspect the system on a regular basis.

C.16 The permitted construction hours are Monday to Friday 7.00am to 6.00pm and Saturday 7.00am to 5.00pm, excepting public holidays. All reasonable steps must be taken to minimise dust generation during the demolition and/or construction process. Demolition and construction noise is to be managed in accordance with the Office of Environment and Heritage Guidelines.

C.17 A Compliance Certificate for the plumbing and drainage work identified in Column 1 at the times specified in Column 2 must be obtained from Council.

COLUMN 1	COLUMN 2
Internal Sewer Drainage	When all internal plumbing and drainage work is installed and prior to concealment.
External Sewer Drainage	When all external plumbing and drainage work is installed and prior to concealment.
Stormwater Drainage	When all external stormwater drainage work is installed and prior to concealment.
Final	Prior to occupation of the building or structure.

Requirements prior to issue of an Occupation Certificate or prior to operation

- C.18 Prior to the issue of an Occupation Certificate for the works a minimum of 20,000 litres of water supply must be dedicated on site for the purposes of bushfire protection. The tank/s dedicated for bushfire protection are required to be:-
- (a) Constructed from non-combustible materials such as metal or concrete.
 - (b) Fitted with a metal 65mm storz fitting with a ball or gate valve provided.
 - (c) Truck access shall be provided within 4m of the water tank for fire tankers.

- (d) A petrol or diesel pump to be enclosed / shielded in a non-combustible housing.
- (e) Tanks on the hazard side of a building are to be provided with adequate shielding for the protection of fire fighters.

NOTE: An alternate solution assessed and approved under the relevant provisions of the Planning for Bush Fire Protection Manual 2006 may satisfy this condition.

- C.19 Prior to issue of an occupation certificate the building number must be displayed in a position clearly visible from the street in letters having a height of not less than 75 mm. The number must be visible against the background on which it is placed.
- C.20 Prior to the issue of an Occupation Certificate the provision of 50,000 litres of water is required for domestic purposes. This is in addition to the dedicated supply required for bushfire purposes.

NOTE: NSW Health advise that proper maintenance of the rainwater tank, catchment system, roof, gutters and inlet is essential to ensure a safe supply of potable water. In this regard, a first flush system must fitted to the inlet supply pipe work

- C.21 An Occupation Certificate, must be obtained pursuant to Section 6.9 of the Environmental Planning and Assessment Act 1979, from either Council or an accredited certifying authority, prior to occupation of the building.

In order to obtain this, the "Final Occupation Certificate" form must be completed and submitted to Council with all required attachments - failure to submit the completed Occupation Certificate Application form will result in an inability for Council to book and subsequently undertake Occupation Certificate inspection.

NOTE: The issuing of an Occupation Certificate does not necessarily indicate that all conditions of development consent have been complied with. The applicant is responsible for ensuring that all conditions of development consent are complied with.

- C.22 A final inspection must be carried out upon completion of plumbing and drainage work and prior to occupation of the development, prior to the issuing of a final plumbing certificate Council must be in possession of Notice of Works, Certificate of Compliance and Works as Executed Diagrams for the works. The works as Executed Diagram must be submitted in electronic format in either AutoCAD or PDF file in accordance with Council requirements.

All plumbing and drainage work must be carried out by a licensed plumber and drainer and to the requirements of the Plumbing and Drainage Act 2011.

NOTE: Additional fees for inspections at the Plumbing Interim Occupancy / Plumbing Occupation stage may apply. This will depend on the number of inspections completed at this stage of the work/s.

- C.23 Prior to the issue of an Occupation Certificate a Water Plumbing Certificate from Riverina Water County Council shall be submitted to Council.

NOTE 1: The applicant is to obtain a Plumbing Permit from Riverina Water County Council before any water supply/plumbing works commence and a Compliance Certificate upon completion of the works. Contact Riverina Water County Council's Plumbing Inspector on 6922 0618. Please be prepared to quote your Construction Certificate number.

General requirements

- C.24 Property access roads shall comply with section 4.1.3 (2) of Planning for Bush Fire Protection 2006.
- C.25 Landscaping to the site is to comply with the principles of Appendix 5 of Planning for Bush Fire Protection 2006.
- C.26 Water, electricity and gas are to comply with section 4.2.7 of Planning for Bush Fire Protection 2006.
- C.27 Any earthworks (including any structural support or other related structure for the purposes of the development):
 - (a) must not cause a danger to life or property or damage to any adjoining building or structure on the lot or to any building or structure on any adjoining lot, and
 - (b) must not redirect the flow of any surface or ground water or cause sediment to be transported onto an adjoining property, and
 - (c) retained material must have a gradient of at least 5%, and
 - (d) must be constructed in accordance with the approved plans for such work(s).

D. SCHEDULE D - Activity Approval Conditions (Section 68)

N/A

E. SCHEDULE E - Prescribed Conditions

Conditions under this schedule are prescribed conditions for the purposes of section 4.17 (11) of the Environmental Planning and assessment Act 1979.

- E.1 Fulfilment of BASIX commitments (clause 97A EP&A Reg 2000)

The commitments listed in any relevant BASIX Certificate for this development must be fulfilled in accordance with the BASIX Certificate Report, Development Consent and the approved plans and specifications.
- E.2 Compliance with Building Code of Australia and insurance requirements under the Home Building Act 1989 (clause 98 EP&A Reg 2000)
 - (1) For development that involves any building work, the work must be carried out in accordance with the requirements of the Building Code of Australia.
 - (2) In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract of insurance shall be in force before any building work authorised to be carried out by the consent commences.

- (3) For a temporary structure that is used as an entertainment venue, the temporary structure must comply with Part B1 and NSW Part H102 of Volume One of the Building Code of Australia.

NOTE 1: This condition does not apply:

- (a) to the extent to which an exemption is in force under clause 187 or 188 of the Environmental Planning and Assessment Regulation 2000 (the Regulation), subject to the terms of any condition or requirement referred to in clause 187(6) or 188(4) of the Regulation, or
- (b) to the erection of a temporary building, other than a temporary structure to which part (3) of this condition applies.

NOTE 2: In this condition, a reference to the Building Code of Australia is a reference to that Code as in force on the date the application is made for the relevant:

- (a) development consent, in the case of a temporary structure that is an entertainment venue, or
- (b) construction certificate, in every other case.

NOTE 3: There are no relevant provisions in the Building Code of Australia in respect of temporary structures that are not entertainment venues.

E.3 Erection of signs (clause 98A EP&A Reg 2000)

For development that involves any building work, subdivision work or demolition work, a sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:

- (a) showing the name, address and telephone number of the principal certifying authority for the work, and
- (b) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
- (c) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

NOTE 1: This condition does not apply in relation to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

NOTE 2: This condition does not apply in relation to Crown building work that is certified, in accordance with section 6.28 of the Environmental Planning and Assessment Act 1979, to comply with the technical provisions of the State's building laws.

NOTE 3: Principal certifying authorities and principal contractors must also ensure that signs required by this clause are erected and maintained.

E.4 Notification of Home Building Act 1989 requirements (clause 98B EP&A Reg 2000)

Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the principal certifying authority for the development to which the work relates (not being the council) has given the council written notice of the following information:

- (a) in the case of work for which a principal contractor is required to be appointed:
 - (i) the name and licence number of the principal contractor, and
 - (ii) the name of the insurer by which the work is insured under Part 6 of that Act,
- (b) in the case of work to be done by an owner-builder:
 - (i) the name of the owner-builder, and
 - (ii) if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under this condition becomes out of date, further work must not be carried out unless the principal certifying authority for the development to which the work relates (not being the council) has given the council written notice of the updated information.

NOTE: This condition does not apply in relation to Crown building work that is certified, in accordance with section 6.28 of the Environmental Planning and Assessment Act 1979, to comply with the technical provisions of the State's building laws.

E.5 Entertainment venues (clause 98C EP&A Reg 2000)

If the development involves the use of a building as an entertainment venue, the development shall comply with the requirements set out in Schedule 3A of the Environmental Planning and Assessment regulation 2000.

E.6 Maximum capacity signage (clause 98D EP&A Reg 2000)

For the following uses of a building: a sign must be displayed in a prominent position in the building stating the maximum number of persons permitted in the building if the development consent for the use contains a condition specifying the maximum number of persons permitted in the building:

- (a) entertainment venue,
- (b) function centre,
- (c) pub,
- (d) registered club,
- (e) restaurant.

NOTE: Words and expressions used in this condition have the same meanings as they have in the Standard Instrument.

E.7 Shoring and adequacy of adjoining property (clause 98E EP&A Reg 2000)

If the development involves an excavation that extends below the level of the base of the footings of a building, structure or work (including any structure or work within a road or rail corridor) on adjoining land, the person having the benefit of the development consent must, at the person's own expense:

- (a) protect and support the building, structure or work from possible damage from the excavation, and
- (b) where necessary, underpin the building, structure or work to prevent any such damage.

NOTE: This condition does not apply if the person having the benefit of the development consent owns the adjoining land or the owner of the adjoining land has given consent in writing to that condition not applying.

F. SCHEDULE F - General Terms of Approval (Integrated Development)

N/A