



City of Wagga Wagga

INSPECTION REPORT

APPLICANT	Lifestyle Patios 42 Nagle St EAST WAGGA WAGGA NSW 2650					
SUBJECT LAND	ADDRESS: 41 Wollundry Ave WAGGA WAGGA NSW 2650 LOT/DP: Lot 17 DP 771426					
CERTIFICATE NO.	CC20/0073		DATE OF ISSUE: 07/05/2020			
TYPE OF CERTIFICATE	<input checked="" type="checkbox"/> Specified building/subdivision work has been completed and complies with the plans and specifications.					
	<input type="checkbox"/>	Footing	<input type="checkbox"/>	Frame	<input type="checkbox"/>	Floor Slab
	<input type="checkbox"/>	Wet area flashing	<input type="checkbox"/>	Sub floor frame	<input type="checkbox"/>	Stormwater drainage
	<input type="checkbox"/>	Internal drainage	<input type="checkbox"/>	External drainage	<input type="checkbox"/>	Trade Waste
	<input type="checkbox"/>	Stackwork	<input type="checkbox"/>	Final plumbing	<input type="checkbox"/>	Pool backwash
	<input checked="" type="checkbox"/>	Piers				
	Other <input checked="" type="checkbox"/> Conditions have been complied with Give details of the specified condition(s) of the development <u>or</u> complying development certificate and detail the matter the condition relates to and the standards/instruments that the matter is required to comply with. <div style="border: 1px dotted black; padding: 5px;"> Comments: Post at north eastern extent of structure to be bolted to existing min. 200mm thick concrete slab located beneath existing paving. Bolted connection to existing house wall sighted. </div>					
DETERMINATION OF CERTIFICATE	Wagga Wagga City Council confirms that: <input checked="" type="checkbox"/> The above described building/subdivision work has been completed and complies with the attached plans and specifications and the above described aspect of development complies with the prescribed requirement referred to above. <input checked="" type="checkbox"/> The above condition(s) have been complied with and works can continue. <input type="checkbox"/> The Compliance Certificate is FAILED for the following reasons: <div style="border: 1px dotted black; height: 80px; width: 100%;"></div>					
	Inspection Date: 15/05/2020 Name of Council Officer: Mason, Andrew BPB Accreditation No: 3352 Council User ID: MASONANDREWJ					

NOTE: This inspection was completed using an electronic device

This inspection report is not a certificate under Part 4A of the Environmental Planning and Assessment Act 1979.