



City of Wagga Wagga

INSPECTION REPORT

APPLICANT	BP Grace 37 Flack Cres BOOROOMA NSW 2650				
SUBJECT LAND	ADDRESS: 37 Flack Cres BOOROOMA NSW 2650 LOT/DP: Lot 20 DP 1193816				
CERTIFICATE NO.	CC20/0038		DATE OF ISSUE: 04/05/2020		
TYPE OF CERTIFICATE	<input checked="" type="checkbox"/> Specified building/subdivision work has been completed and complies with the plans and specifications.				
	<input checked="" type="checkbox"/> Footing <input type="checkbox"/> Wet area flashing <input type="checkbox"/> Internal drainage <input type="checkbox"/> Stackwork <input type="checkbox"/> Piers	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Frame Sub floor frame External drainage Final plumbing	<input checked="" type="checkbox"/> Floor Slab <input type="checkbox"/> Stormwater drainage <input type="checkbox"/> Trade Waste <input type="checkbox"/> Pool backwash	
	Other <input checked="" type="checkbox"/> Conditions have been complied with Give details of the specified condition(s) of the development <u>or</u> complying development certificate and detail the matter the condition relates to and the standards/instruments that the matter is required to comply with. <div style="border: 1px dotted black; padding: 5px; margin-top: 10px;"> Comments: Ensure final sheet is placed on slab prior to pour, and that it is tied and chaired </div>				
DETERMINATION OF CERTIFICATE	Wagga Wagga City Council confirms that: <input checked="" type="checkbox"/> The above described building/subdivision work has been completed and complies with the attached plans and specifications and the above described aspect of development complies with the prescribed requirement referred to above. <input checked="" type="checkbox"/> The above condition(s) have been complied with and works can continue. <input type="checkbox"/> The Compliance Certificate is FAILED for the following reasons: <div style="border: 1px dotted black; height: 80px; margin-top: 10px;"></div>				
	Inspection Date: 01/06/2020 Name of Council Officer: Brockbank, Joshua BPB Accreditation No: 3253 Council User ID: Brockbankj				

NOTE: This inspection was completed using an electronic device

This inspection report is not a certificate under Part 4A of the Environmental Planning and Assessment Act 1979.