

Property Details

Property Address	38 Bourke St TURVEY PARK NSW 2650
Legal Description	Lot 1 DP 19688
Building Premises:	Shop

The reissue of the Fire Safety Schedule pursuant to section 80A (2) (a) (ii) of the Environmental Planning and Assessment Regulation 2021 to correct errors or omissions in the schedule that requires correction.

Date of re-issue: 19/06/2023

Schedule of Fire Safety Measures

Essential Fire Safety Measure	Standard of Performance
Exit Signs	BCA Clauses E4.5, E4.6 & E4.8; AS2293.1 -2005
Portable Fire Extinguisher	BCA Clause E1.6; AS2444-2001

A copy of this Schedule must be:

1. Attached to your Annual Fire Safety Statement
2. Forwarded to the Council and the Commissioner of Fire & Rescue NSW
3. Prominently displayed in the building with the Annual Fire Safety Statement

Council shall be notified immediately in writing of any deletions or additions to the above-mentioned measures. A report from qualified fire safety practitioner or building certifier will be required for any alterations to be considered.