

Issued under the Environmental Planning and Assessment Act 1979, Sections 109C(1)(c) and 109H

TYPE OF CERTIFICATE	[X] Final occupation certificate [] Change of building use [X] Occupation/use of a new building
APPLICANT	TD Goonan 37 Hardy Ave WAGGA WAGGA NSW 2650
SUBJECT LAND	ADDRESS OF WORK: 4 Foxborough Ave WAGGA WAGGA NSW 2650 LOT/DP: Lot 8 DP 20518
DA / CDC	DA22/0155 DATE OF DETERMINATION: 06/04/2022
BUILDING DETAILS	The building classification must the same as that specified in the development consent or complying development certificate. BCA CLASS: Class 10 (a) [X] Whole of building [] Part of building [X] New [] Existing
CONSTRUCTION CERTIFICATE	CERTIFICATE No: CC22/0386 DATE OF ISSUE: 28/09/2022
REQUIRED ATTACHMENTS	 Copy of development consent or complying development certificate Construction certificate (where relevant) Final fire safety certificate or interim fire safety certificate (where relevant) Other certificates relied on
DETERMINATION	The occupation certificate is: [] APPROVED [X] REFUSED: The reasons for refusal are shown below RIGHT OF APPEAL: Under section 109K where the certifying authority is Council an applicant may appeal to the Land and Environment Court against the refusal to issue an occupation certificate within 12 months from the date of the decision.
CERTIFICATE FINAL	Wagga Wagga City Council confirms that it has been appointed as the principle certifying authority under S.109E, a development consent/CDC is in force with respect to the building, where required, a construction certificate has been issued with respect to the plans and specifications of the building, the building is suitable for occupation or use in accordance with its classification under the BCA, where required, a final safety certificate has been issued for the building and a report from the commissioner of Fire Brigades has been considered. In the case of and Interim Occupation certificate, Council has taken into consideration the health and safety of the occupants of the building.
Name: Tyson, Kelly	BDC Registration No: 3289
Signature:	Date: 05/07/2023
Lagen	
Please note the following information: The final for the shed has been failed because the final plumbing inspection for the whole site has been failed as the Gully for the house is not above the Finished Ground Level. As mentioned at the time of the inspection if you can produce evidence or advice from the plumber that the overflow will drain down away from the house then the inspection for final plumbing can be passed and the final for the shed also passed.	

Document Set ID: 5984706 Version: 1, Version Date: 05/07/2023